



Jim Doyle, Governor
Mary P. Burke, Secretary

June 24, 2005

SAINT-GOBAIN PERFORMANCE PLASTICS
SYNFLEX
BRETT W. SCHULTZ
1199 S CHILLICOTHE RD.
AURORA OH 44202

Re: Description: FIXTURE OR APPLIANCE SUPPLY CONNECTOR
Manufacturer: SAINT-GOBAIN PERFORMANCE PLASTICS
Product Name: BEVERAGE TUBING AND HOSE
Model Number(s): SYNFLEX BEVERAGE TUBING SERIES 4209-0300, 4209-0400, 4209-0600, 4209-0800, 4209-1000, 4209-1200, 4209-1300, 4220-0300, 4220-0400, 4220-0600, 4220-0800, 4220-1000, 4220-1200, 4220-1300, 4227-0300, 4227-0400, 4227-0600, 4227-0800, 4227-1000, 4227-1200 and 4227-1300; SYNFLEX BEVERAGE HOSE SERIES 3223-30, 3223-31, 3223-41, 3223-61, 3223-10, 3224-30, 3224-31, 3224-41, 3224-61, 3224-10, 3227-31, 3227-41, 3227-61, 3228-31, 3228-41 and 3228-61
Product File No: 20050362

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be used in conjunction with beverage dispensers.
- The product is marked as follows:
SYNFLEX 4209-XXXX PE TUBING NSF-51 MAX TEMP 150F SAINT-GOBIN;
SYNFLEX 4220-XXXX PA BARRIER TUBING NSF-51 MAX TEMP 150F SAINT-GOBIN;
SYNFLEX TASTE-RITE 4227-XXXX PET BARRIER TUBE NSF-51 MAX TEMP 150F NSF-61 SK394-001 SAINT-GOBIN (LOT #);
SYNFLEX 3223-XX PA REDLINE PLUS BARRIER HOSE NSF-51 MAX TEMP 150F SAINT-GOBIN;
SYNFLEX 3224-XX PA REDLINE PLUS BARRIER HOSE NSF-51 MAX TEMP 150F SAINT-GOBIN;
SYNFLEX TASTE-RITE 3227-XX PET BARRIER HOSE NSF-51 MAX TEMP 150F NSF-61 SK394-001 SAINT-GOBIN (LOT #); or
SYNFLEX TASTE-RITE 3228-XX PET BARRIER HOSE NSF-51 MAX TEMP 150F NSF-61 SK394-001 SAINT-GOBIN (LOT #)

XXXX after the model number designates the tube or hose size.

This approval supersedes the approval issued on INSERT DATE under product file number 20002167.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov